# **Supplementary Fuseblocks** Type M, For $\frac{13}{32}$ " × $1\frac{1}{2}$ " Fuses 600 Volt, 30 Amps

## **BMA Series**



Catalog Symbol: BMA Series

Type M Supplementary Fuseblocks

For use with any  $\frac{13}{32}$ " ×  $1\frac{1}{2}$ " Fuses

(Bussmann KTK, FNQ, FNM, BAF, BAN and AGU)

Ampere Rating: 1/10 to 30A Voltage Rating: 600V

Withstand Rating: 200,000 RMS Sym. or interrupting

rating of the fuse used, whichever is lower.

#### **Agency Information:**

UL Recognized, UL 512, Guide IZLT2, File E14853 CSA Certified, C22.2 No. 39, Class 6225-01, File 47235


**UL Flammability:** 94VO Material: Thermoplastic

#### **Catalog Data**


Wire Range


	Terminal Type		
Poles	Screw with Quick Connect*	Pressure Plate with Quick Connect*	
Adder	BMA603ASQ	BMA603APQ	
1	BMA6031SQ	BMA6031PQ	
2	BMA6032SQ	BMA6032PQ	
3	BMA6033SQ	BMA6033PQ	•
	Adder 1 2	Screw with Quick	Screw with Quick Poles   Pressure Plate with Quick Connect* Connect*


\*QUICK CONNECT RATED FOR 20A MAXIMUM.



Dimensional Data All dimensions ±.015"







### FUSEBLOCK MARKING (EXAMPLE SHOWN) Bussmann



Fuse blocks feature a unique adder block which can be snapped onto 1-, 2-, or 3-pole blocks to form multi-pole segmented blocks of as many poles as desired.

CE logo denotes compliance with European Union Low Voltage Directive (50-1000Vac, 75-1500Vdc). Refer to Data Sheet: 8002 or contact Bussmann Application Engineering at 636-527-1270 for more information.

The only controlled copy of this Data Sheet is the electronic read-only version located on the Bussmann Network Drive. All other copies of this document are by definition uncontrolled. This bulletin is intended to clearly present comprehensive product data and provide technical information that will help the end user with design applications. Bussmann reserves the right, without notice, to change design or construction of any products and to discontinue or limit distribution of any products. Bussmann also reserves the right to change or update, without notice, any technical information contained in this bulletin. Once a product has been selected, it should be tested by the user in all possible applications

